

## Analisis potensi pemborosan energi listrik di Fakultas Ekonomi Universitas Indonesia = Waste of electricity potential analysis at the Faculty of Economics Universitas Indonesia

Ramadhani Deniartio, author

Deskripsi Lengkap: <https://lib.ui.ac.id/detail?id=20311814&lokasi=lokal>

---

### Abstrak

Mulai langkanya sumber daya alam yang digunakan untuk membangkitkan energi listrik memaksa kita untuk melakukan penghematan energi listrik. Penelitian ini dilakukan untuk mengetahui besarnya potensi pemborosan energi di gedung kuliah Fakultas Ekonomi Universitas Indonesia sehingga dapat dilakukan langkah penghematan terhadap pemborosan yang terjadi. Penelitian ini menggunakan data hasil dari pengamatan terhadap pola dan perilaku konsumsi untuk mengetahui besar penggunaan energi listrik. Sedangkan potensi pemborosan energi dihitung dengan mengurangi penggunaan energi dengan perilaku penghematan energi, yaitu skema yang pertama mematikan peralatan ketika tidak digunakan, skema kedua menggunakan pencahayaan alami untuk penerangan, dan skema ketiga menggunakan peralatan sesuai dengan kebutuhan. Berdasarkan penelitian yang dilakukan, pemborosan energi yang terbesar terjadi pada Gedung A dengan menerapkan skema ketiga yaitu sebesar 5694.74 kWh/bulan atau sebesar Rp.4.511.855/bulan.

.....Because of the scarcity of natural resources used to generate electrical energy, it forces us to save the usage of electrical energy. This study was conducted to determine the amount of waste energy potential in the course building at the Faculty of Economics Universitas Indonesia so that we could do the saving for the waste that occurs. This study used data from the result of observations of patterns and consumption behavior to determine the amount of electrical energy usage. While potential energy waste is calculated by reducing energy usage with energy saving behaviors, which are the first scheme is to turn off equipment when not in use, the second scheme is to use natural light for illumination, and the third scheme is to use equipment as needed. Base on the result of this study, the biggest waste of energy occurs in the Gedung A by applying the third scheme that is equal to 5694.74 kWh/month or Rp.4.511.855/month.