

Evaluasi pemenuhan terhadap standar sarana pencegahan dan penanggulangan kebakaran di Gedung Mina Bahari III Kementerian Kelautan dan Perikanan tahun 2012 = Compliance evaluation of standard means of prevention and control of fire at Mina Bahari III Building Ministry of Marine

Audra Humaira, author

Deskripsi Lengkap: <https://lib.ui.ac.id/detail?id=20330905&lokasi=lokal>

Abstrak

Sistem proteksi kebakaran, sarana penyelamatan jiwa, manajemen penanggulangan kebakaran dan program pemeriksaan dan pemeliharaan sarana tersebut merupakan bagian dari sarana pencegahan dan penanggulangan kebakaran yang harus terdapat pada gedung bertingkat. Tujuan penelitian ini adalah untuk mengetahui pemenuhan sarana pencegahan dan penanggulangan kebakaran di Gedung Mina Bahari III Kementerian Kelautan dan Perikanan tahun 2012 terhadap standar.

Desain penelitian yang digunakan adalah observasional dengan pendekatan cross sectional. Analisis yang dilakukan adalah analisis perbandingan dengan standar yaitu Permen PU No.20 tahun 2009, Permen PU No.26 tahun 2008, Kepmen PU No.10 tahun 2000, SNI 03-3985-2000, NFPA 10,13,14,25,72, dan 101. Hasil penelitian menunjukkan bahwa 19 elemen sistem proteksi kebakaran, 7 elemen sarana penyelamatan jiwa, 16 elemen manajemen penanggulangan kebakaran dan 3 elemen program pemeliharaan dan pemeriksaan sarana pencegahan dan penanggulangan kebakaran tidak sesuai dengan standar.

.....Fire protection system, means of rescue, fire fighting management, and inspection and maintenance program of that means is part of means of prevention and control of fire. The purpose of this research is to know the compliance of of prevention and control of fire at Mina Bahari III Building Ministry of Marine Affairs and Fisheries in 2012 to standard.

Design of this research is observational with cross sectional approach. Analysis conducted is comparison analysis with standard Permen PU No.20 tahun 2009, Permen PU No.26 tahun 2008, Kepmen PU No.10 tahun 2000, SNI 03-3985-2000, NFPA 10,13,14,25,72, and 101.

The result of this research showed that 19 element of fire protection system, 7 element of means of rescue, 16 element of fire fighting management and 3 element of inspection and maintenance program does not according to the standard.