

Sistem monitoring dan mekanisme pengaturan daya listrik menggunakan Scada dan PLC berdasarkan fluktuasi tarif listrik = Monitoring systems and electrical power management mechanism using Scada and PLC according electricity rates fluctuations

Arie Maulana, author

Deskripsi Lengkap: <https://lib.ui.ac.id/detail?id=20331166&lokasi=lokal>

Abstrak

Skripsi ini membahas sistem monitoring dan mekanisme pengaturan daya listrik menggunakan Scada dan Plc Berdasarkan Fluktuasi Tarif Listrik. Daya yang dihasilkan diperoleh dari simulator PV (Labview) dengan daya yang konstan. Daya yang dihasilkan tersebut akan digunakan untuk mensuplai beban primer atau beban primer-sekunder atau juga digunakan untuk mengisi baterai berdasarkan fluktuasi tarif listrik dari PLN. Tujuan dari skripsi ini untuk membandingkan daya yang diperoleh menggunakan Scada dan Plc dengan menggunakan BCU. Penelitian ini dengan melakukan perancangan sebuah alat.

Hasil pengujian membuktikan daya yang diperoleh menggunakan Scada dan Plc hasilnya lebih besar daripada menggunakan BCU. Karena pada sistem BCU, daya yang diperoleh digunakan untuk mensuplai beban dan juga mengisi baterai. Keuntungan jual-beli listrik sistem Scada dan Plc lebih besar dari sistem BCU karena daya yang dihasilkan sistem Scada dan Plc maksimal.

.....This thesis discusses monitoring systems and electrical power management mechanism using scada and plc based electricity rates fluctuations. The power produced by PV simulator (Labview) with constant power. The power produced will be used to supply primary load or primary-secondary load or also used to charge the battery according electricity rates from PLN. The purpose of this thesis to compare the power produced by scada and plc with using bcu. This research by designing a tool.

The test results proved the power produced by Scada and Plc result greater than using the BCU. Because at the BCU system, the power produced is used to supply the load and charge the battery. Advantages of buying and selling electricity Plc and Scada system is larger than the BCU system because the power produced a maximum of Scada and Plc systems.