

# Analisis Sistem Proteksi Kebakaran pada Gedung Fakultas Farmasi Universitas Indonesia dengan menggunakan SNI dan NFPA = Fire Protection System Analysis in Faculty of Pharmacy Building University of Indonesia using SNI and NFPA 2013

Alamsyah Prasetya, author

Deskripsi Lengkap: <https://lib.ui.ac.id/detail?id=20346319&lokasi=lokal>

---

## Abstrak

Penelitian ini membahas mengenai Analisis Sistem Proteksi Kebakaran pada Gedung Fakultas Farmasi Universitas Indonesia dengan Menggunakan SNI dan NFPA tahun 2013. Tujuan dari penelitian ini ingin melihat apakah sistem proteksi kebakaran pada gedung Fakultas Farmasi Universitas Indonesia sudah bisa dikatakan baik atau buruk. Dalam penelitian kali ini, penulis menggunakan ceklis sebagai cara untuk mengetahui baik buruknya sistem proteksi kebakaran, yang tiap-tiap variabelnya mengacu pada SNI dan NFPA. Variabel yang menjadi alat ukur penelitian kali ini adalah baik buruknya sprinkler, APAR, titik panggil manual, alarm, hidran, detektor, dan laboratorium. Selain itu, penulis juga melakukan wawancara mendalam untuk mendapatkan pengayaan informasi kepada pihak-pihak yang dirasa memiliki informasi terkait sistem kebakaran yang ada.

Pada hasil penelitian, berdasarkan hasil ceklis ke enam variabel yang mengacu pada SNI dan NFPA terkait sistem proteksi kebakaran pada gedung Fakultas Farmasi Universitas Indonesia, disimpulkan bahwa sistem proteksi kebakaran yang ada pada Fakultas Farmasi Universitas Indonesia masih belum bisa dikatakan baik. Tidak sesuai keadaan sistem proteksi kebakaran yang ada dengan ketentuan yang berlaku pada SNI dan NFPA, serta kurang baiknya manajemen dalam pengelolaan sistem proteksi kebakaran di gedung Fakultas Farmasi Universitas Indonesia menjadi alasan penulis, mengapa sistem proteksi kebakaran pada gedung Fakultas farmasi Universitas Indonesia belum dapat dikatakan baik.

.....This study discusses the Fire Protection System Analysis at the University of Indonesia Faculty of Pharmacy Building in 2013 by using SNI and NFPA. The purpose of this study wanted to see if the fire protection system in the building of the Faculty of Pharmacy, University of Indonesia can be said to be good or bad. In this study, the authors use the checklist as a way to determine the merits of fire protection systems, which each variable refers to the SNI and NFPA. The variables in this study are the good and bad sprinkler, fire extinguisher, manual call point, alarm, fire hydrant, detector, and laboratory. In addition, the authors also conducted in-depth interviews for the benefit of the information to the parties are deemed to have information related to the existing fire system.

On the results of the study, based on the results of the checklist to six variable that refers to the relevant SNI and NFPA fire protection systems in the building of the Faculty of Pharmacy, University of Indonesia, it was concluded that the existing fire protection system at the Faculty of Pharmacy, University of Indonesia was not good. Incompatibility of the state of the existing fire protection system with the applicable provisions of SNI and NFPA, as well as the lack of good management in the management of the fire protection system in the building of the Faculty of Pharmacy, University of Indonesia become the reason the author, why the fire protection systems in buildings Pharmaceutical Faculty, University of Indonesia can not be said good.