

# Evaluasi kualitas akustik auditorium multifungsi studi kasus auditorium balai sarbini = Evaluation of the quality of architectural acoustic on a multifunctional auditorium case study balai sarbini auditorium

Endah Pratiwi, author

Deskripsi Lengkap: <https://lib.ui.ac.id/detail?id=20411421&lokasi=lokal>

---

## Abstrak

Pertimbangan desain akustik untuk auditorium multifungsi tentu berbeda dengan jenis bangunan lainnya dan membutuhkan penyelesaian akustik yang tepat. Skripsi ini merupakan sebuah evaluasi terhadap kualitas akustik auditorium multifungsi dengan menganalisis objek studi kasus Auditorium Balai Sarbini berdasarkan tiga keadaan yang berbeda: keadaan eksisting (tanpa bantuan sound system), ibadah gereja protestan dan konser musik. Evaluasi kualitas akustik dilakukan berdasarkan teori-teori akustik yang relevan, tinjauan lapangan dan penghitungan waktu dengung (reverberation time) pada Balai Sarbini. Hasil evaluasi menunjukkan Balai Sarbini memiliki kualitas akustik yang cukup baik karena bunyi dapat menyebar dengan merata ke semua penjuru ruangan dan memiliki nilai RT yang sesuai untuk fungsi pidato (speech). Namun, Balai Sarbini dinilai tetap perlu melakukan perbaikan untuk memfasilitasi fungsi konser musik.

<hr>The considerations of acoustical design for a multifunctional auditorium is indeed different than any other ordinary buildings and it really needs a proper acoustic solution. This thesis is an evaluation of acoustical quality of a multifunctional auditorium by analyzing a case study object, Balai Sarbini Auditorium, based on three cases: existing condition (without sound system), protestant church service and music concert. The acoustical evaluation is based on some relevant acoustical theories, site reviews and the calculation of the Balai Sarbini's reverberation time. The result of the evaluation showed that generally Balai Sarbini has a good acoustical quality due to the evenly distributed sound and the reverberation time value is suitable for the speech function. However, Balai Sarbini Auditorium still needs an acoustical quality improvement for music concert function.