

## Gambaran manajemen tanggap darurat kebakaran dan sarana penyelamatan jiwa di gedung Fakultas Farmasi Universitas Indonesia tahun 2016 = Management overview fire emergency response and facility of live saving in Faculty of Pharmacy building University of Indonesia year 2016

Dini Nur Anisa, author

Deskripsi Lengkap: <https://lib.ui.ac.id/detail?id=20430549&lokasi=lokal>

---

### Abstrak

Penelitian ini bertujuan untuk melakukan analisis terhadap gambaran manajemen tanggap darurat kebakaran dan sarana penyelamatan jiwa yang ada di gedung Fakultas Farmasi Universitas Indonesia. Penelitian ini menggunakan metode deskriptif analitik dengan melakukan observasi lapangan, wawancara, dan telaah dokumen. Hasil dari penelitian ini selanjutnya dibandingkan kesesuaiannya dengan Permen PU No. 20/PRT/M/2009, Permen PU No.26/PRT/M/2008, Kepmen PU No. 10/KPTS/2000, SNI 03-1746-2000, SNI 03-6574-2001, dan standar internasional NFPA 101.

Hasil penelitian didapatkan bahwa Fakultas Farmasi Universitas Indonesia belum memiliki manajemen tanggap darurat kebakaran yang sesuai dengan standar. Sarana penyelamatan jiwa yang belum semuanya terpenuhi adalah koridor, pintu darurat, tangga darurat, petunjuk arah jalan keluar, dan pencahayaan darurat. Dari hasil penelitian maka diperlukan pengadaan bagi manajemen tanggap darurat kebakaran dan perbaikan bagi sarana penyelamatan jiwa yang belum memenuhi persyaratan, serta dilakukan pemeliharaan bagi yang sudah terpenuhi.

.....The purpose of the research is to analyze the management overview fire emergency response and facility of life saving in Faculty of Pharmacy building, University of Indonesia. This research used the descriptive analytic metod with performing field overview, interview, and document study. The result of this research will be compared its conformity with Permen PU No. 20/PRT/M/2009. Permen PU No. 26/PRT/M/2008, Kepmen PU No. 10/KPTS/2000, SNI 03-1746-2000, SNI 03-6574-2001, and NFPA 101.

This result shows that Faculty of Pharmacy in University of Indonesia yet to have standard compliant fire emergency response management. The place that yet to have life saving facility including corridor, emergency doors, emergency stares, exit directions, and emergency lightings. From this research conclude that the procurement is required for management of the fire emergency responnse and requirement for the life saving facility wich do not meet the requiremnts, and maintenace for the facility.