

Gap analisis sistem proteksi kebakaran gedung Pusat Administrasi Universitas Indonesia tahun 2017 = Gap analysis fire protection system at Administration Center Building of University of Indonesia in 2017

Putu Kriswidiyanto Saputra, author

Deskripsi Lengkap: <https://lib.ui.ac.id/detail?id=20457817&lokasi=lokal>

Abstrak

Skripsi ini membahas tentang gap analisis sistem proteksi kebakaran yang ada di Gedung Pusat Administrasi Universitas Indonesia pada tahun 2017. Penelitian ini merupakan penelitian deskriptif analitik dengan variable yang diteliti adalah sistem proteksi kebakaran pasif konstruksi bangunan, kompartemen, sarana jalan keluar, tangga darurat, pintu darurat, dan petunjuk jalan keluar dan sistem proteksi kebakaran aktif sprinkler, alarm, detektor, APAR, dan hidran.

Hasil penelitian menunjukkan rata-rata 83 kondisi aktual sesuai dengan peraturan dan masih ada 17 gap dengan peraturan. Standar yang digunakan adalah Peraturan Menteri Pekerjaan Umum No.26/PRT/M/2008, Keputusan Menteri Negara Pekerjaan Umum Nomor 10/KPTS/2000, Peraturan Menteri Tenaga Kerja dan Transmigrasi No.4 tahun 1980, NFPA 13, dan NFPA 72. Dan juga dilakukan perhitungan waktu evakuasi disetiap lantai gedung.

.....

This study discussed about gap analysis of fire protection system in Administration Center Building of University of Indonesia in 2017. This research is analytic descriptive research. The variables studies were passive fire protection system building construction, compartment, means of egress, emergency stairs, emergency doors, and exit sign and active fire protection system sprinklers, fire alarms, detectors, fire extinguisher, and hydrants.

Results showed that an average of 83 is in accordance with the regulation and there were still 17 gap with regulation. The standard used is Peraturan Menteri Pekerjaan Umum No.26 PRT M 2008, Keputusan Menteri Negara Pekerjaan Umum Nomor 10 KPTS 2000, Peraturan Menteri Tenaga Kerja dan Transmigrasi No.4 tahun 1980, NFPA 13, and NFPA 72. And also calculated of evacuation time in every floor of building.