

# Peramalan beban listrik persetengahjam tanggal 25 Desember tahun 2017 dan 2018 pada sistem transmisi Jawa-Bali dengan metode koefisien beban = Electrical load forecasting every half hour on December 25th 2017 and 2018 on Java-Bali transmission system using load coefficient method

Fauziah Putri Oktaviani, author

Deskripsi Lengkap: <https://lib.ui.ac.id/detail?id=20472428&lokasi=lokal>

---

## Abstrak

Skripsi ini melakukan peramalan beban persetengahjam untuk tanggal 25 Desember tahun 2017 dan 2018 menggunakan metode koefisien beban dengan data historis tiga dan empat tahun sebelumnya sebagai acuan. Peramalan beban untuk tanggal 25 Desember 2018 bertujuan untuk mengetahui profil singkat beban persetengahjam pada tanggal tersebut. Dengan membandingkan data peramalan dengan data realisasi, penelitian ini menyatakan bahwa metode koefisien beban dianggap cukup akurat dalam melakukan peramalan pada tanggal 25 Desember 2017; peramalan beban persetengahjam dengan metode koefisien beban memperoleh nilai persentase galat APE sebesar 2,17 ; beban puncak harian pada tanggal 25 Desember 2018 akan terjadi pada pukul 18.30 dengan nilai beban 21.068 MW, sedangkan beban terendahnya akan terjadi pada pukul 07.00 dengan nilai beban 16.364,81 MW.

.....

The focus of this study is to do the electrical forecasting every half hour on December 25th 2017 and 2018 using load coefficient method reference to the historical data. Load forecasting on December 25th, 2018 aims to find out the simple profile of load every half hour on the day. By comparing the forecasting data we have with the realization one, this study indicate that the load coefficient method is considered to be quite accurate for load forecasting on December 25th 2017 peak loads occur half an hour earlier than the forecasting load forecasting every half an hour by load coefficient method obtains absolute percentage error APE of 2,17 daily peak load on December 25th, 2018 will occur at 06.30 PM with load value of 21.068MW, while the lowest load will occur at 07.00 AM with load value of 16.364,81 MW.