

Analisis sistem proteksi kebakaran, sarana penyelamatan jiwa, dan manajemen kebakaran di coca cola europacific partners Cibitung Plant tahun 2021 = analysis of fire protection system, means of escape, and fire management in coca cola europacific partners cibitung plant, 2021.

Debby Eka Putri, author

Deskripsi Lengkap: <https://lib.ui.ac.id/detail?id=20517280&lokasi=lokal>

Abstrak

Penelitian ini bertujuan untuk melakukan analisis gambaran terhadap sistem proteksi kebakaran, sarana penyelamatan jiwa, dan manajemen kebakaran di Mega Distribution Centre Coca Cola Europacific Partners Cibitung Plant. Penelitian ini menggunakan metode deskriptif analitik dengan pendekatan semi kuantitatif melalui observasi online, wawancara, dan telaah dokumen. Analisis data dilakukan dengan membandingkan kondisi aktual dengan Peraturan Menteri Pekerjaan Umum No. 26 Tahun 2008, Peraturan Menteri Pekerjaan Umum No. 20 Tahun 2009, dan Standar Nasional Indonesia. Berdasarkan hasil penelitian, sistem proteksi kebakaran aktif memiliki nilai persentase tingkat pemenuhan sebesar 94% dengan kategori baik, sistem proteksi kebakaran pasif memiliki nilai persentase tingkat pemenuhan sebesar 100% dengan kategori baik, sarana penyelamatan jiwa memiliki nilai persentase tingkat pemenuhan sebesar 100% dengan kategori baik, dan manajemen kebakaran memiliki nilai persentase tingkat pemenuhan sebesar 100% dengan kategori baik. Hasil akhir menunjukkan rata-rata pemenuhan sistem proteksi kebakaran, sarana penyelamatan jiwa, dan manajemen kebakaran di Mega Distribution Centre Coca Cola Europacific Partners Cibitung Plant yaitu sebesar 98,5%. Hal ini menunjukkan bahwa Mega Distribution Centre Coca Cola Europacific Partners Cibitung Plant telah memenuhi standar dan peraturan.

.....The purpose of this research is to analyze the overview of the fire protection system, means of escape, and fire management in Mega Distribution Centre Coca Cola Europacific Partners Cibitung Plant. This research uses a descriptive analytic method with a semi-quantitative approach through online observation, interviews, and document review. Data analysis was carried out by comparing the actual conditions with Peraturan Menteri Pekerjaan Umum No. 26 Tahun 2008, Peraturan Menteri Pekerjaan Umum No. 20 Tahun 2009, dan Standar Nasional Indonesia. Based on the results of the research, the active fire protection system has a fulfillment rate percentage value of 94% with a good category, a passive fire protection system has a 100% compliance rate percentage value in the good category, means of escape has a 100% compliance rate percentage value with a good category, and fire management has a percentage value of 100% compliance rate with good category. The final result showed an average of 98,5% fulfillment of the fire protection system, means of escape, and fire management in Mega Distribution Centre Coca Cola Europacific Partners Cibitung Plant. This shows that the overall fulfillment average at the Mega Distribution Centre Coca Cola Europacific Partners Cibitung Plant has met the requirements in applicable regulations and standards.