

Praktik Kerja di PBF PT Enseval Putera Megatrading (Penyusunan Protokol Pemetaan Suhu Gudang Chiller Pharma di PT Enseval Putera Megatrading Cabang Jakarta 1) = Internship at PBF PT Enseval Putera Megatrading (Preparation of Pharma Chiller Warehouse Temperature Mapping Protocol at PT Enseval Putera Megatrading Jakarta Branch 1)

Ririn Edwatri Maulia, author

Deskripsi Lengkap: <https://lib.ui.ac.id/detail?id=9999920543588&lokasi=lokal>

Abstrak

Penyimpanan dan penanganan obat dan/atau bahan obat harus mematuhi peraturan perundang-undangan. Salah satu kegiatan pemantauan yang dapat dilakukan oleh fasilitas distribusi farmasi adalah dengan pemetaan atau mapping suhu gudang penyimpanan. Untuk memastikan bahwa distribusi suhu penyimpanan produk di gudang chiller pharma ($2-8^{\circ}\text{C}$) memenuhi persyaratan dan mengidentifikasi titik terpanas dan titik terdingin yang akan digunakan sebagai acuan titik pemantauan suhu gudang, perlu dibuat protokol pemetaan suhu sebagai acuan dalam melakukan pengujian pemetaan suhu. Protokol pemetaan suhu dibuat untuk memastikan proses pelaksanaan pemetaan suhu yang dilakukan sesuai dengan regulasi yang berlaku. Penyusunan protokol pemetaan suhu pada gudang Chiller Pharma dengan rentang suhu $2-8^{\circ}\text{C}$ membutuhkan 14 data logger yang masih terkalibrasi menggunakan alat termometer Testo 174-T. Penempatan titik thermometer pada bagian bawah 0,5 m dari lantai, bagian tengah 1,15 m dari lantai, dan bagian atas 1,8 m dari lantai. Jarak termometer pada bagian rak seluruhnya terdapat 3 titik (1, 3, dan 6 m). Uji pemetaan dilakukan selama 3 hari kalender.

.....

Storage and handling of drugs and/or drug ingredients must comply with laws and regulations. One of the monitoring activities that can be carried out by pharmaceutical distribution facilities is by mapping the temperature of the storage warehouse. To ensure that the distribution of product storage temperatures in the pharma chiller warehouse ($2-8^{\circ}\text{C}$) meets the requirements and identifies the hottest and coldest points that will be used as a reference for warehouse temperature monitoring points, a temperature mapping protocol needs to be created as a reference in conducting temperature mapping tests. The temperature mapping protocol is created to ensure that the temperature mapping process is carried out in accordance with applicable regulations. The preparation of a temperature mapping protocol in the Chiller warehouse with a temperature range of $2-8^{\circ}\text{C}$ requires 14 data loggers that are still being calibrated using a Testo 174-T thermometer. The placement of thermometer point at the bottom is 0.5 m from the floor, the middle is 1.15 m from the floor, and the top is 1.8 m from the floor. The distance between the thermometers on the shelves is 3 points in total (1, 3, and 6 m). The mapping test was done for 3 calendar days.