

LAMPIRAN A

TABEL DATA PERCOBAAN DAN THERMOGRAPH IMAGING



I. TABEL PERCOBAAN

TABEL PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL										Keterangan
NO	JENIS	UKURAN (MMSQ)	ARUS PEMBEBANAN (A)		WAKTU PEMBEBANAN (Detik)	TEMPERATUR (°C)				
			x In	In		KABEL	JOINTIN 0.0	JOINTING 0.1	JOINTING 0.2	
					0	27.20	27.20	28.90	20.80	
1	NYA	1,5	1.0 In	24	1	32.17	32.50	30.70	42.50	
2					2	37.13	33.50	31.90	46.00	
3					3	42.10	34.10	33.40	49.60	
4					4	47.07	34.90	34.20	49.30	
5					5	57.00	36.00	34.20	51.70	
6					6	57.20	36.60	36.60	51.60	
7					7	57.40	37.00	37.90	51.70	
8					8	57.60	37.00	37.40	50.70	
9					9	57.80	37.20	37.40	50.10	
10					10	58.00	37.00	36.60	50.00	

TABEL PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL										Keterangan
NO	JENIS	UKURAN (MMSQ)	ARUS PEMBEBANAN (A)		WAKTU PEMBEBANAN (Detik)	TEMPERATUR (°C)				
			x In	In		KABEL	JOINTIN 0.0	JOINTING 0.1	JOINTING 0.2	
1	NYA	1,5	2.0 In	48	1	59.00	48.00	75.10	126.90	
2					2	76.90	70.70	74.40	159.70	
3					3	94.80	76.60	74.50	178.40	
4					4	112.70	76.50	75.70	183.00	
5					5	143.50	77.90	74.80	186.00	
6					6	143.90	69.30	78.20	187.70	
7					7	139.30	68.40	77.30	185.00	
8					8	134.70	66.70	80.70	181.00	
9					9	130.10	66.70	81.30	178.90	
10					10	125.50	67.50	83.00	176.50	

TABEL PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL										Keterangan	
NO	JENIS	UKURAN (MMSQ)	ARUS PEMBEBANAN (A)		WAKTU PEMBEBANAN (Menit)	TEMPERATUR (°C)					
			x ln	ln		KABEL	JOINTING 1	JOINTING 2	JOINTING 3		JOINTING 4
			0	0	0	30.00	28.30	28.20	34.30	33.40	
1	NYA	1,5	1.0 ln	24	5	31.21	53.84	49.40	55.60	47.70	
2			1.5 ln	30	10	31.89	67.17	57.20	67.60	58.80	
3			1.8 ln	43	15	33.86	100.70	72.40	102.40	89.30	Berasap tipis
4			2.0 ln	48	20	34.81	119.00	108.60	129.60	108.10	isolasi menggelembung
5			2.5 ln	60	25	37.51	169.40	136.20	178.80	165.90	isolasi mulai meleleh
6			3.5 ln	75	30	41.73	366.70	199.60	248.30	253.20	isolasi lumer
7			4.0 ln	96	35	-	-	235.60	244.60	256.90	kabel membara
8			4.5 ln	108	40	-	-	-	-	-	
9			5.0 ln	120	45	-	-	-	-	-	

TABEL PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL										Keterangan	
NO	JENIS	UKURAN (MMSQ)	ARUS PEMBEBANAN (A)		WAKTU PEMBEBANAN (Menit)	TEMPERATUR (°C)					
			x ln	ln		KABEL	JOINTING 1	JOINTING 2	JOINTING 3		JOINTING 4
			0	0	0	30.00	31.60	32.30		27.90	
1	NYA	1,5	1.0 ln	24	5	31.21	49.20	53.80		56.80	
2	NYAF		1.5 ln	30	10	31.89	57.40	69.40		67.80	
3			1.8 ln	43	15	33.86	89.90	98.90		124.80	Berasap tipis
4			2.0 ln	48	20	34.81	111.60	124.40		147.00	isolasi mulai menggelembung
5			2.5 ln	60	25	37.51	255.10	160.00		252.60	isolasi mulai meleleh
6			3.5 ln	75	30	41.73	494.60	256.60		269.80	isolasi lumer
7			4.0 ln	96	35	-	-	-		-	kabel membara
8			4.5 ln	108	40	-	-	-		-	
9			5.0 ln	120	45	-	-	-		-	


**PHOTO PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL
TYPE JOINTING - 00**

Visual Image



TYPE	SAMBUNGAN O
DATE	11 JANUARI 2008
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
JENIS KABEL	KABEL " NYA "
UKURAN	1.5 MM
ARUS BEBAN	24 A
TAHAP MENIT	0

Thermal Image



TEMPERATURE DATA (° C)	
JOINTING	27.1 ° C
SPOT-1	27.2 ° C
SPOT-2	27.2 ° C
SPOT-3	° C

Probable Causes

	Comment / Suggestion

Client Supervisors Notes


**PHOTO PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL
TYPE JOINTING - 00**

Visual Image



TYPE	SAMBUNGAN O
DATE	11 JANUARI 2008
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
JENIS KABEL	KABEL " NYA "
UKURAN	1.5 MM
ARUS BEBAN	24 A
TAHAP MENIT	05

Thermal Image



TEMPERATURE DATA (° C)	
JOINTING	35.0 ° C
SPOT-1	56.2 ° C
SPOT-2	66.2 ° C
SPOT-3	57.0 ° C

Probable Causes

	Comment / Suggestion

Client Supervisors Notes


**PHOTO PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL
TYPE JOINTING - 00**

Visual Image



TYPE	SAMBUNGAN O
DATE	11 JANUARI 2008
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
JENIS KABEL	KABEL " NYA "
UKURAN	1.5 MM
ARUS BEBAN	24 A
TAHAP MENIT	10

Thermal Image



TEMPERATURE DATA (° C)	
JOINTING	37.0 ° C
SPOT-1	49.8 ° C
SPOT-2	66.1 ° C
SPOT-3	58.0 ° C

Probable Causes

	Comment / Suggestion

Client Supervisors Notes


**PHOTO PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL
TYPE JOINTING - 00**

Visual Image



TYPE	SAMBUNGAN O
DATE	11 JANUARI 2008
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
JENIS KABEL	KABEL " NYA "
UKURAN	1.5 MM
ARUS BEBAN	48 A
TAHAP MENIT	1

Thermal Image



TEMPERATURE DATA (° C)	
JOINTING	46.0 ° C
SPOT-1	49.7 ° C
SPOT-2	61.0 ° C
SPOT-3	59.0 ° C

Probable Causes

	Comment / Suggestion

Client Supervisors Notes


**PHOTO PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL
TYPE JOINTING - 00**

Visual Image



TYPE	SAMBUNGAN O
DATE	11 JANUARI 2008
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
JENIS KABEL	KABEL " NYA "
UKURAN	1.5 MM
ARUS BEBAN	48 A
TAHAP MENIT	5

Thermal Image



TEMPERATURE DATA (° C)	
JOINTING	77.7 ° C
SPOT-1	125.2 ° C
SPOT-2	178.1 ° C
SPOT-3	148.5 ° C

Probable Causes

	Comment / Suggestion
	ASAP AGAK TEBAL

Client Supervisors Notes


**PHOTO PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL
TYPE JOINTING - 00**

Visual Image



TYPE	SAMBUNGAN O
DATE	11 JANUARI 2008
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
JENIS KABEL	KABEL " NYA "
UKURAN	1.5 MM
ARUS BEBAN	48 A
TAHAP MENIT	10

Thermal Image



TEMPERATURE DATA (° C)	
JOINTING	68.5 ° C
SPOT-1	128.2 ° C
SPOT-2	171.5 ° C
SPOT-3	125.5 ° C

Probable Causes

	Comment / Suggestion

Client Supervisors Notes


**TABEL PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL
TYPE JOINTING - 01**

Visual Image



TYPE	SAMBUNGAN 3
DATE	11 JANUARI 2008
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
JENIS KABEL	KABEL " NYA "
UKURAN	1.5 MM
ARUS BEBAN	24 A
TAHAP MENIT	0

Thermal Image



TEMPERATURE DATA (° C)	
JOINTING	30.6 ° C
SPOT-1	33.0 ° C
SPOT-2	32.4 ° C
SPOT-3	° C

Probable Causes

	Comment / Suggestion

Client Supervisors Notes


**PHOTO PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL
TYPE JOINTING - 01**

Visual Image



TYPE	SAMBUNGAN 3
DATE	11 JANUARI 2008
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
JENIS KABEL	KABEL " NYA "
UKURAN	1.5 MM
ARUS BEBAN	24 A
TAHAP MENIT	5

Thermal Image



TEMPERATURE DATA (° C)	
JOINTING	36.3 ° C
SPOT-1	145.3 ° C
SPOT-2	99.8 ° C
SPOT-3	° C

Probable Causes

	Comment / Suggestion

Client Supervisors Notes


**PHOTO PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL
TYPE JOINTING - 01**

Visual Image



TYPE	SAMBUNGAN 3
DATE	11 JANUARI 2008
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
JENIS KABEL	KABEL " NYA "
UKURAN	1.5 MM
ARUS BEBAN	24 A
TAHAP MENIT	10

Thermal Image



TEMPERATURE DATA (° C)	
JOINTING	46.5 ° C
SPOT-1	174.8 ° C
SPOT-2	144.6 ° C
SPOT-3	104.8 ° C

Probable Causes

	Comment / Suggestion

Client Supervisors Notes


**PHOTO PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL
TYPE JOINTING - 01**

Visual Image



TYPE	SAMBUNGAN 3
DATE	11 JANUARI 2008
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
JENIS KABEL	KABEL " NYA "
UKURAN	1.5 MM
ARUS BEBAN	48 A
TAHAP MENIT	0

Thermal Image



Temperature Data (° C)	
JOINTING	30.6 ° C
SPOT-1	33.0 ° C
SPOT-2	32.4 ° C
SPOT-3	° C

Probable Causes

	Comment / Suggestion

Client Supervisors Notes


**PHOTO PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL
TYPE JOINTING - 01**

Visual Image



TYPE	SAMBUNGAN 3
DATE	11 JANUARI 2008
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
JENIS KABEL	KABEL " NYA "
UKURAN	1.5 MM
ARUS BEBAN	48 A
TAHAP MENIT	05

Thermal Image



TEMPERATURE DATA (° C)	
JOINTING	75.0 ° C
SPOT-1	186.5 ° C
SPOT-2	158.5 ° C
SPOT-3	° C

Probable Causes

	Comment / Suggestion

Client Supervisors Notes


**PHOTO PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL
TYPE JOINTING - 01**

Visual Image



TYPE	SAMBUNGAN 3
DATE	11 JANUARI 2008
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
JENIS KABEL	KABEL " NYA "
UKURAN	1.5 MM
ARUS BEBAN	48 A
TAHAP MENIT	10

Thermal Image



TEMPERATURE DATA (° C)	
JOINTING	83.2 ° C
SPOT-1	173.0 ° C
SPOT-2	156.5 ° C
SPOT-3	° C

Probable Causes

	Comment / Suggestion

Client Supervisors Notes


**PHOTO PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL
TYPE JOINTING - 02**

Visual Image



TYPE	SAMBUNGAN 4 CRUSTIN
DATE	11 JANUARI 2008
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
JENIS KABEL	KABEL " NYA "
UKURAN	1.5 MM
ARUS BEBAN	24 A
TAHAP MENIT	0

Thermal Image



TEMPERATURE DATA (° C)	
JOINTING	27.8 ° C
SPOT-1	28.6 ° C
SPOT-2	27.7 ° C
SPOT-3	° C

Probable Causes

Comment / Suggestion

Client Supervisors Notes

--


**PHOTO PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL
TYPE JOINTING - 02**

Visual Image



TYPE	SAMBUNGAN 4 CRUSTIN
DATE	11 JANUARI 2008
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
JENIS KABEL	KABEL " NYA "
UKURAN	1.5 MM
ARUS BEBAN	24 A
TAHAP MENIT	5

Thermal Image



TEMPERATURE DATA (° C)	
JOINTING	51.6 ° C
SPOT-1	49.4 ° C
SPOT-2	60.1 ° C
SPOT-3	° C


Probable Causes

	Comment / Suggestion

Client Supervisors Notes


**PHOTO PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL
TYPE JOINTING - 02**

Visual Image



TYPE	SAMBUNGAN 4 CRUSTIN
DATE	11 JANUARI 2008
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
JENIS KABEL	KABEL " NYA "
UKURAN	1.5 MM
ARUS BEBAN	24 A
TAHAP MENIT	10

Thermal Image



TEMPERATURE DATA (° C)	
JOINTING	50.9 ° C
SPOT-1	51.8 ° C
SPOT-2	75.1 ° C
SPOT-3	° C

Probable Causes

	Comment / Suggestion

Client Supervisors Notes


**PHOTO PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL
TYPE JOINTING - 02**

Visual Image



TYPE	SAMBUNGAN 4 CRUSTIN
DATE	11 JANUARI 2008
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
JENIS KABEL	KABEL " NYA "
UKURAN	1.5 MM
ARUS BEBAN	48 A
TAHAP MENIT	0

Thermal Image



TEMPERATURE DATA (° C)	
JOINTING	30.0 ° C
SPOT-1	31.6 ° C
SPOT-2	30.1 ° C
SPOT-3	

Probable Causes

	Comment / Suggestion

Client Supervisors Notes


**PHOTO PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL
TYPE JOINTING - 02**

Visual Image



TYPE	SAMBUNGAN 4 CRUSTIN
DATE	11 JANUARI 2008
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
JENIS KABEL	KABEL " NYA "
UKURAN	1.5 MM
ARUS BEBAN	48 A
TAHAP MENIT	5

Thermal Image



TEMPERATURE DATA (° C)	
JOINTING	186.1 ° C
SPOT-1	144.9 ° C
SPOT-2	172.0 ° C
SPOT-3	

Probable Causes

	Comment / Suggestion

Client Supervisors Notes


**PHOTO PERCOBAAN KEMAMPUAN HANTAR ARUS KABEL
TYPE JOINTING - 02**

Visual Image



TYPE	SAMBUNGAN 4 CRUSTIN
DATE	11 JANUARI 2008
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
JENIS KABEL	KABEL " NYA "
UKURAN	1.5 MM
ARUS BEBAN	48 A
TAHAP MENIT	10

Thermal Image



TEMPERATURE DATA (° C)	
JOINTING	176.6 ° C
SPOT-1	133.7 ° C
SPOT-2	174.4 ° C
SPOT-3	

Probable Causes

	Comment / Suggestion

Client Supervisors Notes

INFRARED THERMOGRAPHY REPORT

Visual Image





PHOTO NO.	01
DATE	10 DESEMBER 2007
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO. 1 LAS DOP

Thermal Image



TEMPERATURE DATA (° C)

ARUS NOMINAL	0 A
TAHAP 5 MENIT KE	I
TEMPERATURE SAMBUNGAN	28.4 ° C
HOT SPOT KABEL	28.7 ° C

CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE

Probable Causes

	Comment / Suggestion
Bad Connection	KABEL MASIH NORMAL
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes

INFRARED THERMOGRAPHY REPORT

Visual Image





PHOTO NO.	02
DATE	10 DESEMBER 2007
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO. 1 LAS DOP

Thermal Image



TEMPERATURE DATA (° C)

ARUS NOMINAL	24 A
TAHAP 5 MENIT KE	II
TEMPERATURE SAMBUNGAN	53.84 ° C
HOT SPOT KABEL	59.60 ° C

CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE

Probable Causes

	Comment / Suggestion
Bad Connection	KABEL MASIH NORMAL
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes

INFRARED THERMOGRAPHY REPORT

Visual Image





PHOTO NO.	05
DATE	10 DESEMBER 2007
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO. 1 LAS DOP

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	48 A
TAHAP 5 MENIT KE	V
TEMPERATURE SAMBUNGAN	121.7 ° C
HOT SPOT KABEL	155.1 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

	Comment / Suggestion
Bad Connection	KABEL SUDAH BER ASAP
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes


INFRARED THERMOGRAPHY REPORT

Visual Image



PHOTO NO.	07
DATE	10 DESEMBER 2007
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO. 1 LAS DOP

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	75 A
TAHAP 5 MENIT KE	VII
TEMPERATURE SAMBUNGAN	366.7 ° C
HOT SPOT KABEL	221.9 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

	Comment / Suggestion
Bad Connection	KABEL SUDAH BER ASAP
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes

INFRARED THERMOGRAPHY REPORT

Visual Image





PHOTO NO.	08
DATE	10 DESEMBER 2007
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO. 1 LAS DOP

Thermal Image



TEMPERATURE DATA (° C)

ARUS NOMINAL	90 A
TAHAP 5 MENIT KE	VIII
TEMPERATURE SAMBUNGAN	404.7 ° C
HOT SPOT KABEL	268.8 ° C

CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE

Probable Causes

	Comment / Suggestion
Bad Connection	KABEL SUDAH MEMBARA
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes

INFRARED THERMOGRAPHY REPORT

Visual Image





PHOTO NO.	09
DATE	10 DESEMBER 2007
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.2 PUNTIR 1

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	0 A
TAHAP 5 MENIT KE	I
TEMPERATURE SAMBUNGAN	31.7 ° C
HOT SPOT KABEL	33.5 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

Probable Causes	Comment / Suggestion
Bad Connection	KABEL NORMAL
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes

INFRARED THERMOGRAPHY REPORT

Visual Image





PHOTO NO.	10
DATE	10 DESEMBER 2007
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.2 PUNTIR 1

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	24 A
TAHAP 5 MENIT KE	II
TEMPERATURE SAMBUNGAN	49.4 ° C
HOT SPOT KABEL	52.3 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

	Comment / Suggestion
Bad Connection	KABEL NORMAL
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes

INFRARED THERMOGRAPHY REPORT

Visual Image





PHOTO NO.	13
DATE	10 DESEMBER 2007
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.2 PUNTIR 1

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	48 A
TAHAP 5 MENIT KE	V
TEMPERATURE SAMBUNGAN	108.6 ° C
HOT SPOT KABEL	110.3 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

Probable Causes	Comment / Suggestion
Bad Connection	MULAI BERASAP
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes

--


INFRARED THERMOGRAPHY REPORT

Visual Image



PHOTO NO.	15
DATE	10 DESEMBER 2007
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.2 PUNTIR 1

Thermal Image



TEMPERATURE DATA (° C)

ARUS NOMINAL	75 A
TAHAP 5 MENIT KE	VII
TEMPERATURE SAMBUNGAN	199.6 ° C
HOT SPOT KABEL	209.3 ° C

CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE

Probable Causes

	Comment / Suggestion
Bad Connection	SUDAH TERBAKAR
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes


INFRARED THERMOGRAPHY REPORT

Visual Image



PHOTO NO.	17
DATE	10 DESEMBER 2007
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.2 PUNTIR 1

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	90 A
TAHAP 5 MENIT KE	VIII-up
TEMPERATURE SAMBUNGAN	250.1 ° C
HOT SPOT KABEL	234.6 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

	Comment / Suggestion
Bad Connection	SUDAH MEMBARA MEMBARA
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes

INFRARED THERMOGRAPHY REPORT

Visual Image





PHOTO NO.	18
DATE	10 DESEMBER 2007
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.3 PUNTIR 2

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	0 A
TAHAP 5 MENIT KE	I
TEMPERATURE SAMBUNGAN	34.4 ° C
HOT SPOT KABEL	34.4 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

	Comment / Suggestion
Bad Connection	SAMBUNGAN MASIH NORMAL
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes

INFRARED THERMOGRAPHY REPORT

Visual Image





PHOTO NO.	19
DATE	10 DESEMBER 2007
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.3 PUNTIR 2

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	24 A
TAHAP 5 MENIT KE	II
TEMPERATURE SAMBUNGAN	55.6 ° C
HOT SPOT KABEL	56.8 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

	Comment / Suggestion
Bad Connection	SAMBUNGAN MASIH NORMAL
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes

INFRARED THERMOGRAPHY REPORT

Visual Image





PHOTO NO.	22
DATE	10 DESEMBER 2007
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.3 PUNTIR 2

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	48 A
TAHAP 5 MENIT KE	V
TEMPERATURE SAMBUNGAN	129.6 ° C
HOT SPOT KABEL	133.3 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

	Comment / Suggestion
Bad Connection	SAMBUNGAN SUDAH MULAI BERASAP
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes


INFRARED THERMOGRAPHY REPORT

Visual Image



PHOTO NO.	25
DATE	10 DESEMBER 2007
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.3 PUNTIR 2

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	75 A
TAHAP 5 MENIT KE	VIII
TEMPERATURE SAMBUNGAN	244.6 ° C
HOT SPOT KABEL	255.9 ° C

CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

	Comment / Suggestion
Bad Connection	SUDAH MULAI MEMBARA
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes

INFRARED THERMOGRAPHY REPORT

Visual Image





PHOTO NO.	26
DATE	10 DESEMBER 2007
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.3 PUNTIR 2

Thermal Image



TEMPERATURE DATA (° C)

ARUS NOMINAL	96 A
TAHAP 5 MENIT KE	IX
TEMPERATURE SAMBUNGAN	256.1 ° C
HOT SPOT KABEL	255.9 ° C

CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE

Probable Causes

	Comment / Suggestion
Bad Connection	SUDAH MEMBARA
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes


INFRARED THERMOGRAPHY REPORT

Visual Image



PHOTO NO.	27
DATE	10 DESEMBER 2007
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.4 CRUSTIN

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	0 A
TAHAP 5 MENIT KE	I
TEMPERATURE SAMBUNGAN	33.4 ° C
HOT SPOT KABEL	35.5 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

	Comment / Suggestion
Bad Connection	SAMBUNGAN MASIH NORMAL
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes


INFRARED THERMOGRAPHY REPORT

Visual Image



PHOTO NO.	28
DATE	10 DESEMBER 2007
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.4 CRUSTIN

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	24 A
TAHAP 5 MENIT KE	II
TEMPERATURE SAMBUNGAN	47.7 ° C
HOT SPOT KABEL	52.8 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

	Comment / Suggestion
Bad Connection	SAMBUNGAN MASIH NORMAL
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes


INFRARED THERMOGRAPHY REPORT

Visual Image



PHOTO NO.	31
DATE	10 DESEMBER 2007
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.4 CRUSTIN

Thermal Image



TEMPERATURE DATA (° C)

ARUS NOMINAL	48 A
TAHAP 5 MENIT KE	V
TEMPERATURE SAMBUNGAN	108.1 ° C
HOT SPOT KABEL	108.4 ° C

CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE

Probable Causes

	Comment / Suggestion
Bad Connection	SAMBUNGAN MULAI BERASAP
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes


INFRARED THERMOGRAPHY REPORT

Visual Image



PHOTO NO.	33
DATE	10 DESEMBER 2007
RISER BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.4 CRUSTIN

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	75 A
TAHAP 5 MENIT KE	VII
TEMPERATURE SAMBUNGAN	253.2 ° C
HOT SPOT KABEL	204.4 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

	Comment / Suggestion
Bad Connection	SAMBUNGAN BERASAP TEBAL
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes


INFRARED THERMOGRAPHY REPORT

Visual Image



PHOTO NO.	34
DATE	10 DESEMBER 2007
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.3 CRUSTIN

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	96 A
TAHAP 5 MENIT KE	VIII
TEMPERATURE SAMBUNGAN	256.9 ° C
HOT SPOT KABEL	272.0 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

	Comment / Suggestion
Bad Connection	SAMBUNGAN MULAI MEMBARA
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes


INFRARED THERMOGRAPHY REPORT

Visual Image



PHOTO NO.	35
DATE	10 DESEMBER 2007
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYAF + NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.5 CRUSTIN

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	0 A
TAHAP 5 MENIT KE	I
TEMPERATURE SAMBUNGAN	32.1 ° C
HOT SPOT KABEL	33.5 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

	Comment / Suggestion
Bad Connection	SAMBUNGAN MASIH NORMAL
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes

INFRARED THERMOGRAPHY REPORT

Visual Image





PHOTO NO.	36
DATE	10 DESEMBER 2007
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYAF + NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.5 CRUSTIN

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	24 A
TAHAP 5 MENIT KE	II
TEMPERATURE SAMBUNGAN	53.8 ° C
HOT SPOT KABEL	53.2 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

	Comment / Suggestion
Bad Connection	SAMBUNGAN MASIH NORMAL
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes

INFRARED THERMOGRAPHY REPORT

Visual Image





PHOTO NO.	39
DATE	10 DESEMBER 2007
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYAF + NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.5 CRUSTIN

Thermal Image



TEMPERATURE DATA (° C)

ARUS NOMINAL	48 A
TAHAP 5 MENIT KE	V
TEMPERATURE SAMBUNGAN	124.4 ° C
HOT SPOT KABEL	125.2 ° C

CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE

Probable Causes

	Comment / Suggestion
Bad Connection	SAMBUNGAN SUDAH MULAI BERASAP PADA KABEL SERBUK
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes

--	--


INFRARED THERMOGRAPHY REPORT

Visual Image



PHOTO NO.	41
DATE	10 DESEMBER 2007
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYAF + NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.5 CRUSTIN

Thermal Image



TEMPERATURE DATA (° C)

ARUS NOMINAL	75 A
TAHAP 5 MENIT KE	VII
TEMPERATURE SAMBUNGAN	160.0 ° C
HOT SPOT KABEL	158.3 ° C

CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE

Probable Causes

	Comment / Suggestion
Bad Connection	SAMBUNGAN SUDAH MEMBARA
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes


INFRARED THERMOGRAPHY REPORT

Visual Image



PHOTO NO.	42
DATE	10 DESEMBER 2007
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYAF + NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.5 CRUSTIN

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	96 A
TAHAP 5 MENIT KE	VIII
TEMPERATURE SAMBUNGAN	256.6 ° C
HOT SPOT KABEL	228.6 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

	Comment / Suggestion
Bad Connection	KABEL SUDAH MEMBARA
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes


INFRARED THERMOGRAPHY REPORT

Visual Image



PHOTO NO.	43
DATE	10 DESEMBER 2007
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYAF + NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.6 PUNTIR

Thermal Image



TEMPERATURE DATA (° C)

ARUS NOMINAL	0 A
TAHAP 5 MENIT KE	I
TEMPERATURE SAMBUNGAN	27.9 ° C
HOT SPOT KABEL	28.1 ° C

CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE

Probable Causes

Bad Connection	Comment / Suggestion
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

SAMBUNGAN MASIH NORMAL

Client Supervisors Notes

--

INFRARED THERMOGRAPHY REPORT

Visual Image





PHOTO NO.	44
DATE	10 DESEMBER 2007
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYAF + NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.6 PUNTIR

Thermal Image



TEMPERATURE DATA (° C)

ARUS NOMINAL	24 A
TAHAP 5 MENIT KE	II
TEMPERATURE SAMBUNGAN	56.8 ° C
HOT SPOT KABEL	48.9 ° C

CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE

Probable Causes

	Comment / Suggestion
Bad Connection	SAMBUNGAN MASIH NORMAL
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes

INFRARED THERMOGRAPHY REPORT

Visual Image





PHOTO NO.	47
DATE	10 DESEMBER 2007
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYAF + NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.6 PUNTIR

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	48 A
TAHAP 5 MENIT KE	V
TEMPERATURE SAMBUNGAN	147.0 ° C
HOT SPOT KABEL	81.9 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

	Comment / Suggestion
Bad Connection	SUDAH BERASAP BANYAK
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes


INFRARED THERMOGRAPHY REPORT

Visual Image



PHOTO NO.	49
DATE	10 DESEMBER 2007
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYAF + NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.6 PUNTIR

Thermal Image



TEMPERATURE DATA (° C)

ARUS NOMINAL	75 A
TAHAP 5 MENIT KE	VII
TEMPERATURE SAMBUNGAN	269.8 ° C
HOT SPOT KABEL	252.3 ° C

CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE

Probable Causes

	Comment / Suggestion
Bad Connection	MULAI MEMBARA
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes


INFRARED THERMOGRAPHY REPORT

Visual Image



PHOTO NO.	50
DATE	10 DESEMBER 2007
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYAF + NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.6 PUNTIR

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	90 A
TAHAP 5 MENIT KE	VIII
TEMPERATURE SAMBUNGAN	269.8 ° C
HOT SPOT KABEL	252.3 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

	Comment / Suggestion
Bad Connection	SUDAH MEMBARA
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes

INFRARED THERMOGRAPHY REPORT

Visual Image





PHOTO NO.	51
DATE	10 DESEMBER 2007
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYAF + NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.7 LASDOP

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	0 A
TAHAP 5 MENIT KE	I
TEMPERATURE SAMBUNGAN	31.6 ° C
HOT SPOT KABEL	33.3 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

	Comment / Suggestion
Bad Connection	SAMBUNGAN KABEL MASIH NORMAL
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes

INFRARED THERMOGRAPHY REPORT

Visual Image





PHOTO NO.	52
DATE	10 DESEMBER 2007
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYAF + NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.7 LASDOP

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	24 A
TAHAP 5 MENIT KE	II
TEMPERATURE SAMBUNGAN	49.2 ° C
HOT SPOT KABEL	47.8 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

	Comment / Suggestion
Bad Connection	SAMBUNGAN KABEL MASIH NORMAL
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes


INFRARED THERMOGRAPHY REPORT

Visual Image



PHOTO NO.	55
DATE	10 DESEMBER 2007
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYAF + NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.7 LASDOP

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	48 A
TAHAP 5 MENIT KE	V
TEMPERATURE SAMBUNGAN	111.6 ° C
HOT SPOT KABEL	119.7 ° C
CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE	

Probable Causes

	Comment / Suggestion
Bad Connection	SUDAH MULAI BERASAP AGAK BANYAK
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes


INFRARED THERMOGRAPHY REPORT

Visual Image



PHOTO NO.	57
DATE	10 DESEMBER 2007
RISET BY	ADRIIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYAF + NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.7 LASDOP

Thermal Image



TEMPERATURE DATA (° C)	
ARUS NOMINAL	75 A
TAHAP 5 MENIT KE	VII
TEMPERATURE SAMBUNGAN	255.1 ° C
HOT SPOT KABEL	216.6 ° C

CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE

Probable Causes

	Comment / Suggestion
Bad Connection	SUDAH MULAI MELELEH
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes

--


INFRARED THERMOGRAPHY REPORT

Visual Image



PHOTO NO.	58
DATE	10 DESEMBER 2007
RISET BY	ADRIANUS PANGARIBUAN
LOCATION	FAKULTAS TEKNIK UI
EQUIPMENT	KABEL " NYAF + NYA 1,5 MM"
OBJECT	TYPE SAMBUNGAN NO.7 LASDOP

Thermal Image



TEMPERATURE DATA (° C)

ARUS NOMINAL	96 A
TAHAP 5 MENIT KE	VIII
TEMPERATURE SAMBUNGAN	494.6 ° C
HOT SPOT KABEL	497.8 ° C

CLASSIFICATION OF RISE IN TEMPERATURE FROM PERMITTED MAXIMUM TEMPERATURE

Probable Causes

	Comment / Suggestion
Bad Connection	SUDAH MEMBARA
Overload	
Unbalance Loaded	
Internal Component / Parts failure	
Electromagnetic Induction	
Normal Operating Temperature	

Client Supervisors Notes

LAMPIRAN B

TABEL DAN DATA TEKNIS



Tabel 7.6-1 Penghantar dengan bahan isolasi, pembebanan dan pemasangannya harus memperhatikan suhu batas yang diperbolehkan

No.	Jenis Isolasi	Nomenklatur	Untuk kabel pasangan tetap			Untuk kabel fleksibel		
			Suhu Penghantar maksimum °C	Suhu keliling		Suhu penghantar maksimum °C	Suhu keliling	
				maksimum °C	minimum °C		maksimum °C	minimum °C
1.	Polyvinyl chloride biasa	Y biasa	70	60	+ 5	70	60	+ 5
2.	Polyvinyl chloride special	Y special	90	80	+ 5	-	-	-
3.	Karet biasa	G	60	50	- 25	60	50	- 25
4.	Karet Butil	2 G	85	75	- 25	85	75	- 25
5.	Karet Silikon	Si	-	-	-	180	170	25
6.	Polyethylene	2Y	70	60	- 25	-	-	-
7.	Cross linked Polyethylene (XLPE)	2 X	90	75	- 25	85	75	-25
8.	Ethylene Propylene Rubber	EPR	90	75	- 25	85	75	- 25
9.	Mineral	- biasa - special	85 250	60 -	- 25 -	- -	- -	- -
10.	Kertas	-	85	45	-	-	-	-

Tabel 7.3 - 40 Resistans penghantar (kabel) instalasi tetap pada suhu 20 °C (R₂₀)

Luas penampang nominal mm ²	Jumlah minimum kawat	Berlapis logam		Polos		Aluminium	
		Inti tunggal	Inti banyak	Inti tunggal	Inti banyak	Inti tunggal	Inti banyak
		ohm/km	ohm/km	ohm/km	ohm/km	ohm/km	ohm/km
1	2	3	4	5	6	7	8
0,5	1	36,0	36,7	35,3	36,0	-	-
0,75	1	24,3	24,8	24,0	24,5	-	-
1	1	17,9	18,2	17,7	18,1	29,3	29,9
1,5	1	12,0	12,2	11,9	12,1	19,7	20,0
2,5	1	7,21	7,35	7,14	7,28	11,8	12,0
4	1	4,51	4,60	4,47	4,56	7,39	7,54
6	1	3,0	3,06	2,97	3,03	4,91	5,01
10	1	1,79	1,83	1,77	1,81	2,94	3,0
16	1	1,13	1,15	1,12	1,14	1,85	1,89
0,5	7	42,4	43,10	41,7	42,40	-	-
0,75	7	27,0	27,50	26,8	27,0	-	-
1	7	21,2	21,60	20,8	21,20	34,8	35,4
1,5	7	13,6	13,80	13,3	13,60	22,2	22,7
2,5	7	7,41	7,56	7,27	7,41	12,1	12,4
4	7	4,6	4,70	4,52	4,61	7,55	7,70
6	7	3,05	3,11	3,02	3,08	4,99	5,09
10	7	1,81	1,84	1,79	1,83	2,96	3,02
16	7	1,41	1,16	1,13	1,15	1,87	1,91
25	7 (19)	0,719	0,734	0,712	0,727	1,18	1,20
35	19	0,519	0,529	0,514	0,524	0,851	0,868
50	19	0,383	0,391	0,379	0,387	0,628	0,641
70	7	0,265	0,270	0,262	0,268	0,435	0,443
95	7	0,191	0,195	0,189	0,193	0,313	0,320
120	7	0,151	0,154	0,150	0,153	0,248	0,253
150	7	0,123	0,126	0,122	0,124	0,202	0,206
185	7	0,0982	0,100	0,0972	0,0991	0,161	0,164
240	7	0,0747	0,0762	0,0740	0,0754	0,122	0,125
300	7 (19)	0,0595	0,0607	0,059	0,0601	0,976	0,100
400	19	0,0465	0,0475	0,0461	0,0470	0,0763	0,0778
500	19	0,0369	0,0377	0,0366	0,0373	0,0605	0,0617

Rumus menghitung resistans pada suhu t :

$$R_t = R_{20} \times \frac{234,5 + t}{254,5} \times \frac{L}{1000} \text{ untuk tembaga}$$

$$R_t = R_{20} \times \frac{228 + t}{248} \times \frac{L}{1000} \text{ untuk aluminium}$$

dimana R_t = resistans L meter kabel pada suhu t derajat C, dalam ohm
 R_{20} = resistans pada 20 derajat C, dalam ohm/km
t = suhu penghantar, dalam derajat C
L = panjang penghantar, dalam m


Faktor koreksi untuk menghitung resistans penghantar pada suhu berbeda dengan 20 °C.

Tabel 7.3-2 Faktor koreksi untuk KHA terus menerus untuk kabel instalasi berinti tunggal berisolasi karet/PVC pada suhu keliling 30 °C dengan suhu penghantar maksimum 70 °C

Suhu keliling °C	% dari nilai KHA menurut Tabel 7.3-1 kolom 4	
	Bahan isolasi karet	Bahan isolasi PVC
1	2	3
$t \leq 30^\circ\text{C}$	98	100
$30^\circ\text{C} < t \leq 35^\circ\text{C}$	90	94
$35^\circ\text{C} < t \leq 40^\circ\text{C}$	80	87
$40^\circ\text{C} < t \leq 45^\circ\text{C}$	69	80
$45^\circ\text{C} < t \leq 50^\circ\text{C}$	56	71
$50^\circ\text{C} < t \leq 55^\circ\text{C}$	40	62

Tabel 7.3-3 Faktor koreksi untuk KHA terus menerus untuk kabel instalasi tunggal berisolasi terbuat dari bahan khusus tahan panas pada suhu keliling di atas 55 °C


Suhu keliling °C		% dari nilai menurut Tabel 7.3-1 kolom 4
Penghantar dengan batas suhu kerja 100 °C	Penghantar dengan batas suhu kerja 180 °C	
1	2	3
$55^\circ\text{C} < t \leq 65^\circ\text{C}$	$55^\circ\text{C} < t \leq 145^\circ\text{C}$	100
$65^\circ\text{C} < t \leq 70^\circ\text{C}$	$145^\circ\text{C} < t \leq 150^\circ\text{C}$	92
$70^\circ\text{C} < t \leq 75^\circ\text{C}$	$150^\circ\text{C} < t \leq 155^\circ\text{C}$	85
$75^\circ\text{C} < t \leq 80^\circ\text{C}$	$155^\circ\text{C} < t \leq 160^\circ\text{C}$	75
$80^\circ\text{C} < t \leq 85^\circ\text{C}$	$160^\circ\text{C} < t \leq 165^\circ\text{C}$	65
$85^\circ\text{C} < t \leq 90^\circ\text{C}$	$165^\circ\text{C} < t \leq 170^\circ\text{C}$	53
$90^\circ\text{C} < t \leq 95^\circ\text{C}$	$170^\circ\text{C} < t \leq 175^\circ\text{C}$	38




Proteksi motor jalan atau beban lebih harus disetel dekat pada arus pengenalnya. Pemilihan penghantar ditentukan oleh KHA yang dihitung seperti di atas.

Gambar 5.5-2 Contoh pada 5.5.6.1

Umum	5.5.1
Kedaaan lingkungan	5.5.2
Ketentuan untuk tegangan di atas 1000 V	5.5.10
Pencegahan terhadap sentuhan	5.5.11
Pembumian	5.5.12





PROSPECTIVE CURRENT, r.m.s. AMPERES

fig. 4

Time/Current characteristics for fuses to BS 1361

FUSE RATING	CURRENT FOR TIME			
	0.1 sec	0.2 sec	0.4 sec	5 sec
5A	30A	25A	22A	14A
15A	97A	80A	70A	46A
20A	180A	155A	135A	82A
30A	280A	240A	200A	125A
45A	550A	470A	400A	240A
60A	880A	720A	600A	330A
80A	1100A	950A	800A	460A
100A	1800A	1400A	1200A	630A




fig. 1 PROSPECTIVE CURRENT, r.m.s. AMPERES

TABLE 52B (Regulation 523-01)

Maximum conductor operating temperatures

Conductor material	Insulation material	Conductor operating temperature °C limit	Limiting final fault temperature °C	Appendix 4 Table
Copper	70° C p.v.c. (General purpose)	70	160/140*	4D 1-2-3&4
	60° C rubber	60	200	4H1
	85° C rubber	85	220	4F 1 & 2
	85° C p.v.c.	85	160	
	90° C thermosetting Impregnated paper	90 80	250 160	4E 1-2-3 & 4
Mineral - plastic covered or exposed to touch - bare and neither exposed to touch nor in contact with combustible materials		70 105	160 250	4J1 4J2
Aluminium	70° C p.v.c. (General purpose)	70	160/140*	4K 1-2-3 & 4
	60° C rubber	60	200	
	85° C rubber	85	220	
	90° C thermosetting Impregnated paper	90 80	250 160	4L 1-2-3 & 4

* above 300 mm²